

Compliance Statement

No. 2022-485

Screened Permanent Link, Class Ea

Company

Ultima
Cardinal Way
Cardinal Distribution Park
Godmanchester
Huntingdon PE29 2 XJ
United Kingdom

Permanent Link Identification (2 connector model)

Horizontal cable:

Ultima Cat6A F/FTP LSZH Cca Light Blue
Part number: 810360

RJ45 connector for telecommunications outlet, equipment outlet:

Ultima Keystone Jack Cat6A Toolless 180 Deg HD Shielded White Shutter
Part number 816144

Generic cabling standards - Class Ea Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12225691-02, DANAK-19/22819

EC Cabling product ID


6918

CS valid until

1 September 2023

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 21 July 2022



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

