

Compliance Statement

No. 2022-484

Screened Channel, Class E_A

Company

Ultima
Cardinal Way
Cardinal Distribution Park
Godmanchester
Huntingdon PE29 2XJ
United Kingdom

Channel Identification (4 connector model)

Horizontal cable:

Ultima Cat6A F/FTP LSZH Cca Light Blue
Part number: 810360

RJ45 connector for telecommunications outlet, consolidation point, equipment outlet:

Ultima Keystone Jack Cat6A Toolless 180 Deg HD Shielded White Shutter
Part number 816144

Consolidation point cord (5 m, 2 pcs):

Ultima Solid Core Patch Lead Cat6A F/FTP
Part number: 820455 (incl. jack 816144 for CP)

Terminal cord, equipment cord:

Ultima Patch Lead Cat6A F/UTP LSZH Moulded Boot Grey 5m
Part number: 791505

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12225691-01, DANAK-19/22822

EC Cabling product ID


6917

CS valid until

1 September 2023

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 21 July 2022



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

